



**WOODSIDE FIRE PROTECTION DISTRICT**  
PRESS RELEASE

August 19, 2009

FOR IMMEDIATE RELEASE

Contact Information:

Selena Brown, Public Education Officer

Woodside Fire Protection District

(650) 423-1406 Direct

(650) 366-1064 Fax

[Selenab@woodsidefire.org](mailto:Selenab@woodsidefire.org) email

[www.woodsidefire.org](http://www.woodsidefire.org)

The U.S. Consumer Product Safety Commission issued the following press release on July 9<sup>th</sup>, 2009. The Woodside Fire Protection District urges all of its residents to check their smoke alarms for brand name, model number, and date of manufacture. If you have one or more of the recalled smoke alarms, follow the instructions given in the press release.

**News from CPSC**

**U.S. Consumer Product Safety Commission**

**Office of Information and Public Affairs Washington, D.C. 20207**

**For Immediate Release**

**July 9, 2009 CPSC**

**Release #09-266 CPSC**

**Kidde Recalls Dual Sensor Smoke Alarms; Can Fail to Warn of a Fire**

**Firm's Recall Hotline: (877) 524-2086**

**Recall Hotline: (800) 638-2772**

**Media Contact: (301) 504-7908**

WASHINGTON, D.C. – The U.S. Consumer Product Safety Commission, in cooperation with the firm named below, today announced a voluntary recall of the following products. Consumers should stop using recalled products immediately unless otherwise instructed.

**Name of Product:** Kidde Model PI2000 Dual Sensor Smoke Alarms

**Units:** About 94,000

**Manufacturer:** Walter Kidde Portable Equipment Inc., of Mebane, N.C.

**Hazard:** An electro static discharge can damage the unit, causing it not to warn consumers of a fire.

**Incidents/Injuries:** The firm has received two reported incidents of smoke alarm malfunctions involving electro static discharge during installation. No injuries have been reported.

**Description:** This recall involves Kidde dual sensor smoke alarms model PI2000. The alarms can be identified by two buttons, "HUSH" and "PUSH AND HOLD TO TEST WEEKLY," which are located on the

front/center of the alarm. The model number and date code are on the back of the smoke alarm. Only date codes 2008 Aug.01 through 2009 May 04 are included in this recall.

**Sold at:** Retail, department, and hardware stores and through electrical distributors nationwide from August 2008 through May 2009 for between \$30 and \$40.

**Manufactured in:** China

**Remedy:** Consumers should contact Kidde immediately to receive a free replacement smoke alarm.

**Customer Contact:** For additional information, contact Kidde toll-free at (877) 524-2086 between 8 a.m. and 5 p.m. ET Monday through Friday, or visit the firm's Web site at [www.kidde.com](http://www.kidde.com).

