

WOODSIDE

FIRE

PROTECTION

DISTRICT

**Residential Fire Sprinkler System
GENERATOR Requirements**



4091 Jefferson Ave · Redwood City, CA · 94062 · Fire Marshal 851.6206 · Fax 650.366-1064

Generators must have a permanent placard showing location and instructions for turning off generator.

****NOTE****

Must have a permanent placard stating:

**CAUTION MAIN ELECTRICAL SERVICE HAS
BACKUP GENERATOR POWER SOURCE**

Generator plan check fee is \$60.00.
This includes one plan check and 1 inspection.