

Woodside Fire Protection District

Prevention Division

SOLAR PHOTOVOLTAIC SYSTEM REVIEW

rev 2/08

In collaboration with the State Fire Marshal's office, the Woodside Fire Protection District, (WFPD) has developed a standard of conditions to ensure firefighter and public safety for all Solar PV systems. WFPD appreciates the environmental friendly technologic advances these systems bring. However, traditional firefighting techniques, such as roof venting, water extinguishment and fire overhaul will have to be modified to ensure human safety. Roofs that contain Solar arrays will be most difficult for firefighters to vent. Delayed roof venting may increase the time factor in fire containment resulting in a greater extent of fire damage overall. Conventional water extinguishment on roofs with Solar PV systems may not be an option for firefighters if the integrity of any portion of the Solar array is threatened as the risk of accidental electrocution is greatly increased. Fire overhaul will also be a challenge for firefighters, as broken panels or compromised Solar conduit will remain energized during daylight hours or when illuminated by lights.

The following conditions will apply to all roof and ground mount Solar PV systems:

1. There will be a minimum of 36" of clearance at the ridge line where Solar Array's are installed on roofs. Arrays are allowed to be installed down to the eave if there remains (3) three access points from the ground to the ridge. If there is less than (3) three access points to the roof ridge then there shall remain a 36" perimeter of walking area around the array.
2. Ground mounted Solar arrays will be erected in areas clear of combustible vegetation. A minimum vegetation clearance or mowed perimeter of 10' shall be maintained.
3. All Solar conduits, interior or exterior, will be permanently labeled with fade resistant material stating: **CAUTION: Solar PV Wiring May Remain Energized After Disconnection During Daylight Hours** *(see attached signage req)*
4. Permanent placard installed on exterior and interior of main electrical panel stating: **CAUTION: Solar PV System Installed-When Power Disconnected Solar Panels And Wiring May Remain Energized During Daylight Hours**
5. Battery storage in enclosed rooms to be mounted a minimum of 24" above floor. If contained within cabinet a permanent placard to be posted.
6. All disconnects shall be accessible to fire department and located together when possible.



Woodside Fire Protection District

Prevention Division

7. A separate emergency disconnect on roof to disconnect solar panels from interior and exterior wiring running to inverter. This disconnect must be permanently labeled, in reflective, fade resistant material, “**Emergency Disconnect**”

I have read the above safety concerns involved in the installation of a Solar PV system and understand the conditions set forth above.

Signed by _____ Date _____

Print Name _____

SIGNAGE REQUIREMENTS FOR SOLAR PV SYSTEMS

Two forms of signage are required for Solar PV Systems. Permanently affixed reflective labels should have a white background with red lettering. Printed material should resist fading. Size of lettering should be equal to the example below.

1. Exterior/Interior Conduit signage:

Horizontal and Vertical to be installed every 20'. For vertical conduit a minimum of 1 label to be affixed at eye level.

<p><u>CAUTION</u> Solar PV Wiring May Remain Energized After Disconnection During Daylight Hours.</p>
--

2. Exterior/Interior of Electrical Panel signage:

<p><u>CAUTION</u> Solar PV System Installed. When Power Disconnected Solar Panels And Wiring In Conduit May Remain Energized During Daylight Hours.</p>
--