



**WOODSIDE FIRE PROTECTION DISTRICT**  
***Residential/Commercial Generator***

**Submittal Requirements**

**808 Portola Rd. Portola Valley, CA 94028 Fire Prevention 650-423-1405 Fax 650-851-3960**

Woodside Fire Protection District requires plans to be submitted through the local building department. Plans will be reviewed and approved by Woodside Fire Prevention Bureau. Along with the submittal package a \$180.00 (Plan review fee) will be required. *Checks payable to Woodside Fire Protection District*

**\*\*NOTE\*\***

**If your project is under review through County of San Mateo Planning and Building Departments. Fees for your project need to be directly paid to WFPD prior to plan approval.**

The information provided in this document is general and intended as a guide only. Each project is unique and additional requirements may be enforced as deemed appropriate.

**Residential/Commercial Generator:**

***ALL SIGNAGE, LABELS AND PLACARDS WILL BE; RED SIGN WITH WHITE LETTERS***

- 1- All combustible materials must be kept clear 5' around generator.
- 2- Generator must have a shutdown switch.
- 3- Generator will have permanent placard showing location and instructions for turning off generator.
- 4- Main Electrical Panel will have a signage.  
Will read; *CAUTION* Main Electrical Service has Backup Generator Power Source.