



WOODSIDE FIRE PROTECTION DISTRICT

Prevention Division

808 Portola Rd. #C Portola Valley, CA 94028 ~ Fire Marshal Don Bullard 650-851-6206 djbullard@woodsidefire.org

FIRE PROTECTION PLAN CHECK SHEET

For compliance with 2007 CBC Chapter 7A

PROJECT LOCATION:	Jurisdiction: -----
Owner/Architect/Project Manager:	Permit#:

The intent of this fire protection plan is to outline and manage ways to minimize and mitigate potential loss from wildfire exposure.

THE FOLLOWING MUST BE INCLUDED:

The intent of this fire protection plan is to outline and describe the methods and timetables in which the existing flammable fuels within 100 feet of any building or structure will be removed to mitigate the risk and potential loss from wildfire exposure. The plan should include water supply, access, building ignition and fire-resistance factors and if there are any fire protection systems and equipment on site

FIRE PROTECTION PLAN ELEMENTS: attach site plan and any additional pages

- 1. Site Plan:**
- 2. Description of the methods and timetables for removing and/or modifying existing flammable fuels within 100 feet of any building or structure (2019 CFC sec. 304.1.2) and within 50 feet of the perimeter property line (2019 CFC sec. 304.1.2A)**
:
- 3. A Description of the plan for maintaining the proposed fuel-reduction measures:**
Elements of the plan shall include the removal of weeds, grass, vines, or other growth that is capable of being ignited and endangering property. Non-fire-resistive vegetation or growth shall be kept clear 100 feet or to the property line, of buildings and structures in such a manner as to provide a clear area for fire suppression operations. Trees are allowed within the defensible space, provided limbs located less than 6 feet above the ground have been removed and the horizontal distance between crowns of adjacent trees, structures, overhead electrical facilities and unmodified fuel is not less than 10 feet. Deadwood and litter shall be regularly removed from trees and property premises).

Reviewed by:-----

Date:

Resubmit

Approved with Conditions

Approved without conditions

WFPD Comments: